

# Medical Facility Federal Tax Deduction Lighting Design Guidance

## Medical Facility - Building Area Method

Description	REF	25% Improvement as compared to 2007 Standard \$0.30/sq.ft. Deduction Watts/sq.ft.	40% Improvement as compared to 2007 Standard \$0.60/sq.ft. Deduction Watts/sq.ft.
Building Area Method - Medical	1.2	0.9	0.72

## Typical Spaces in a Medical Facility

Description	REF	25% Improvement as compared to 2007 Standard \$0.30/sq.ft. Deduction Watts/sq.ft.	40% Improvement as compared to 2007 Standard \$0.60/sq.ft. Deduction Watts/sq.ft.
Lobby	1.3	0.975	0.78
Corridors	0.5	0.375	0.3
Lounge/Recreation	1.2	0.9	0.72
Conference/Meeting/Multipurpose	1.3	0.975	0.78
Parking Garage	0.2	0.15	0.12
Restrooms	0.9	0.675	0.54
Food Prep	1.2	0.9	0.72
Enclosed Office	1.1	0.825	0.66
Open Office	1.1	0.825	0.66
Electrical/Mechanical	1.5	1.125	0.9
Storage	0.8	0.6	0.48
Stairways	0.6	0.45	0.36
Laboratory	1.4	1.05	0.84

Please direct any questions you have on the new tax law standards to Energy Tax Savers at [www.Energytaxsavers.com](http://www.Energytaxsavers.com), [charles.goulding@energytaxsavers.com](mailto:charles.goulding@energytaxsavers.com), or 516 364 2630